



Government of Karnataka

TALUK HEALTH OFFICE BANGALORE EAST TALUK, K. R. PURAM, BANGALORE
PHONE NO:080-25612400 EMAIL ID:thobangaloreeast2@gmail.com

REF:THO/NO:74/2025-26

Date:15.07.2025

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY
CONDITION CERTIFICATE**

It is certified that an inspection team headed by **Dr. B.B. RAGUNATH** I/C Taluk Health Officer, from Taluk Health Office, Bengaluru East Taluk, Bengaluru Urban District Health and Family Welfare Department inspected the **VELS GLOBAL SCHOOL, 92/1, 7th CROSS, 2/1, TULSI THEATRE ROAD, MARATHAHALLI VILLAGE, MARATHAHALLI, BENGALURU KARNATAKA - 560037**, on 15.07.2025 checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building and the campus as per the norms prescribed by the Central/State/U.T Govt.

The above is valid for period of one year.

Signature :Dr.B.B. Ragunath
Designation: Taluk Health Officer.

To:
The Chairman/Principal,
Vels Global School,
92/1, 7th Cross, 92/1, Tulsi Theater Road,
Marathahalli Village, Marathahalli,
Bengaluru, Karnataka - 560037.

TALUK HEALTH OFFICE
East Taluk, K.R Puram
Bengaluru Urban District



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.
NABL Accredited Laboratory Bangalore urban

TEST REPORT

Address of the sampling location : VELS Global School
 92/1, 7th Cross, 92/1, Tulsi Theater Road, Marathahalli
 Village, Marathahalli
 Bengaluru-560037

Report date: 05/07/2025
 Report Number: 003
 Reference: TRF
 Sample code: 003
 Date of Sample collection: 04/07/2025
 Analysis start date: 04/07/2025
 Analysis completion date: 05/07/2025
 Sample quantity: 1 Liter

Sample Particulars: R O water

Sl. No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1	pH Value @25°C Temp	7.0	6.5 - 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, $\mu\text{S}/\text{cm}$ @25°C Temp	70	-	-	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2012
4	Colour, Hazen Units	< 1.0	5	15	IS 3025 (Part-4) : 2021
5	Turbidity, NTU	0.0	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids, mg/l @180°C	40	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as CaCO_3 , mg/l	16.7	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as CaCO_3 , mg/l	12.0	200	600	IS 3025 (Part-21) : 2023
9	Calcium as Ca, mg/l	3.2	75	200	IS 3025 (Part-40) : 1991
10	Magnesium as Mg, mg/l	1.9	30	100	IS 3025 (Part-46) : 2023
11	Chloride as Cl, mg/l	7.5	250	1000	IS 3025 (Part-32) : 1982
12	Sulphate as SO_4 , mg/l	4.1	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l	Nil	1	1.5	APHA 24 th Edition
14	Nitrate as NO_3 , mg/l	3.2	45	No relaxation	APHA 24 th Edition
15	Iron as Fe, mg/l	0.0	1	No relaxation	IS 3025 (Part-53) : 2003

Remark: The above given sample conforms to the Acceptable limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.

Analysed by: *Megha K.C.*
 Senior Analyst/Junior Analyst

Authorized Signatory: *Pavithra B.S.*
 Technical Manager: Pavithra B.S.



RDWSD/WQMSF/TeR/01

Note:

- The above results relate only to the sample tested.
- The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- Samples will be discarded after 15 days from the date of report generation.
- Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSF/DR-01

--END--